

# Fire Retardant Specifications

Test	ThoroShield™ - Nylon Reinforced Vinyls					DuraShield™ - Woven Reinforced Polyethylenes				
	TS 650 FR	TS 750 FR	TS 950 FR	TS 1050 FR	DS 2000 FR	DS 3000 FR	DS 4000 A) FR	DS 6000 FR	DS 8000 FR	
CPAI Spec.84 Section 6	X	X	X	X	X	X	X	X	X	
CPAI Spec.84 Section 7	X	X	X	X		X	X	X	X	
NFPA 701 Small Scale	X	X	X	X		X	X	X	X	
NFPA 701 Large Scale	X	X	X	X		X	X	X	X	
Boston Fire Prevention Code Article 11-2	X	X	X	X		X	X	X	X	
California State Fire Marshall Code	X	X	X	X		X	X	X	X	
City of New York Board of Standards and Appeals Cal.No. 294-40-SR	X	X	X	X		X	X	X	X	
US Bureau of Mines Dept. of Labor / MSHA ASTM E-162								X	X	
Tunnel Burn Test ASTM E-84	X	X	X	X		X	X	X	X	
Fed. Std. 191; Method 5903 Extinguish Time & Char. Length	X	X	X	X						
ANSI 45.2.2 Nuclear Specification	X	X	X	X				X	X	
American Nuclear Insurers Nuclear Mutual Limited	*	*	*	*			*	*	*	

\* Products Listed Meet Requirements But Require Independent Certification.

## THOR Enterprises, Inc.